

CERTIFICATE OF CONFORMITY

Product Listing Scheme: Scheme Type 5

This certificate is issued to: Hilti Far East Pte Ltd
20 Harbour Drive
#06-06 PSA VISTA
Singapore 117612

Registration Number/UEN: 196800338E

Product: Fire Stopping Material

Brand: Hilti

Model: CP 670

Country of Origin: The Netherlands

Product Details: Fire Stop Coating
See COC Appendix (1 page) for Fire Performance

Standard(s): BS 476-20:1987

Report(s): WARRES No. 124662 & 124663
WFRC No. C129497
WF Report No. 392166c

This certificate issued in accordance with SCDF Fire Code 2018 requirements.



Head of Certification



Certificate No.	Date of Original Issue	No. of Page(s)	Date of Last Revision	Date of Expiry
20A0301	02 July 2020	1 of 2	-	01 December 2022

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of Singapore Test Services Pte Ltd ("STS") and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme of STS. The above certified company is solely responsible for compliance of any product that has the same designation as the product type tested. Parties relying on this Certificate should verify its validity with STS.



APPENDIX

Product Details:

Fire Performance of Penetration Gap Sealing System

Construction

Application	Gaps
Concrete & dry wall with mineral fibre insulation batts provided for penetration services. (Both sides or six edges of the batts to be coated with CP 670)	All gaps between the penetration services, wall and fire barrier to be sealed up with CP 606

Fire Performance

No.	Penetration Services	Integrity (Mins)	Insulation (Mins)
1	No Service (Blank Seal)	240	240
2	Copper Pipe up to Dia. 108mm	240	-
3	Steel Pipe up to Dia. 250mm	240	30
4	Mild Steel Trunking	120	30
5	Galvanized Steel Cable Tray	180	120
6	Cable (Size: $\varnothing \leq 20\text{mm}$)	180	120
7	Cable (Size: $20\text{mm} < \varnothing \leq 40\text{mm}$)	180	120
8	Cable (Size: $40\text{mm} < \varnothing \leq 75\text{mm}$)	180	120
9	Polyethylene Pipe (Installed with CP 642 Collar (Surface Mounted))	240	60
10	Polyethylene Pipe (Installed with CP 642 Collar (Recessed))	240	60
11	Damper (Size: 450mm high x 450mm wide)	240	-

Head of Certification

Certificate No.
20A0301

Date of Original Issue
02 July 2020

No. of Page(s)
2 of 2

Date of Last Revision
-

Date of Expiry
01 December 2022

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of Singapore Test Services Pte Ltd ("STS") and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme of STS. The above certified company is solely responsible for compliance of any product that has the same designation as the product type tested. Parties relying on this Certificate should verify its validity with STS.