

CERTIFICATE OF CONFORMITY

Product Listing Scheme: Scheme Type 5

This certificate is issued to: Hilti Far East Pte Ltd
20 Harbour Drive
#06-06 PSA VISTA
Singapore 117612

Registration Number/UEN: 196800338E

Product: Fire Stopping Material

Brand: Hilti

Model: CFS-SP SIL

Country of Origin: Germany

Product Details: Fire Stopping Material For Curtain Wall Application
F Rating: 120mins ; T Rating: 30mins

Standard(s): ASTM E2307-19

Report(s): Intertek No. 101339442SAT-002, 101339442SAT-004
Intertek Letter No. 103116256SAT-001, 104345837SAT-001

This certificate issued in accordance with SCDF Fire Code 2018 requirements.



Head of Certification



Certificate No.	Date of Original Issue	No. of Page(s)	Date of Last Revision	Date of Expiry
20A0292	02 June 2020	1 of 1	-	01 June 2025

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of Singapore Test Services Pte Ltd ("STS") and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme of STS. The above certified company is solely responsible for compliance of any product that has the same designation as the product type tested. Parties relying on this Certificate should verify its validity with STS.