

Confirmation

LEED

On 1 Oktober 2014, Eurofins Product Testing A/S received a sample of a sealant with the product name:

CP606 = CFS-S ACR

supplied by

Hilti Entwicklungsgesellschaft GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested as Waterproofing concrete/Masonry sealers in accordance with the relevant ISO 16000, AgBB, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2014-00218205_02 and 392-2014-00261503rev2_02).

The test results of the tested adhesive indicate that the product qualifies for LEED 2009 and LEED v4 specifications on VOC emissions and/or VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m³ after 28 days

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of SCAQMD rule 1168 (2005)

21 April 2015



Maria Pelle
Chemist



Janne R. Norup
Chemist