

Certificate of Compliance

Certificate Number **20060214-R13240**
Report Reference **2006 February 14**
Issue Date **2006 February 14**

Page 1 of 1



Issued to: **Hilti, Inc.**
5400 S 122ND East Ave
Tulsa, OK 74146 USA


This is to certify that representative samples of **Fill, Void or Cavity Materials**
CP601S

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: **ANSI/UL 1479, ANSI/UL 2079, CAN/ULC-S115-05**


Additional Information: **CP601S Sealant for use in Joint Systems and CP601S Sealant for use in Through-Penetration Firestop Systems as currently described in the UL Fire Resistance Directory.**

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:

Mona Couloute
Underwriters Laboratories Inc.

Reviewed by:

Christopher Johnson
Underwriters Laboratories Inc.