

Confirmation

LEED

On 21 December 2015, Eurofins Product Testing A/S received a sample of firestop sealing with the product name:

Hilti CFS-TTS

supplied by

Hilti Entwicklungsgesellschaft GmbH


The sample was supplied as being representative of the manufactured product, and it has been tested as solid firestop product in accordance with the relevant ISO 16000, AgBB and CDPH testing standards (See test report no. 392-2015-00422301_C and 392-2015-00422301_H).

The test results of the tested flooring indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 $\mu\text{g}/\text{m}^3$ after 28 days
- the requirements of CDPH-IAQ (California Department of Public Health, Feb 2010); and a TVOC below 0.5 mg/m^3 in both office and class room.

15 February 2016



Thomas Bjerring
Analytical Service Manager



Janne R. Norup
Chemist